



NOTES:

ALL FLOW RATES ARE GIVEN IN GPM.

FLOW RATES ARE BASED ON FULL LOAD OPERATION, ANNUAL AVERAGE TEMPERATURE OF 61 DEGREES F, 53 WB.

COOLING TOWER BLOWDOWN IS BASED ON MAINTAINING 10 CYCLES OF CONCENTRATION.

FLOW RATES ARE BASED ON FOLSOM SOUTH CANAL WATER CONSTITUENTS SPECIFIED.

Figure 2.2-6bR
Cosumnes Power Project
Phase II – Annual Average
WATER BALANCE DIAGRAM
PB POWER, INC.